

Zadatok : 112100004

Task No.

Br. strana : 10


Pages

Strana : 1

Page

Aneks : 0

Annexes



IZVEŠTAJ O ISPITIVANJU
FUNKCIONALNIH I RADNIH KARAKTERISTIKA
TEST REPORT ON FUNCTIONAL AND OPERATIONAL PROPERTIES

Br. / No. 112100004 / 314 / 2

Naziv proizvoda - tip
Product Name - Type

: Nadzemni požarni hidrant, Tip NH21A5, DN 100, PN 16,
izlazi 2 x B + 1 x A
Pillar fire hydrant, Type NH21A5, DN 100, PN 16, outlets 2 x B + 1 x A

Proizvođač
Manufacturer

: „TECOOP-ENG“ d.o.o.,
26000 Pančevo, Savska 12-14, SRBIJA / SERBIA

Podnosilac
Applicant

: „TECOOP-ENG“ d.o.o.,
26000 Pančevo, Savska 12-14, SRBIJA / SERBIA

Uzorak
Sample data

: Dostavljeno od strane podnosioca dana 01.07.2011.
Submitted by the applicant on 01.07.2011

Broj uzoraka
Number of samples

: 1 kom tipa NH21A5 ("A"), DN 100, PN 16, reg. br. uzorka 314/331/11/2
1 pc of type NH21A5 („A“), DN 100, PN 16, sample reg. No. 314/331/11/2

Metoda ispitivanja, podaci o
postupku, broj standarda
Test method, process data
Standard Number

: MPS 314/1.2.1, MPS 314/2.2.1 i MPS 314/3.1.1
EN 14384: 2005, EN 1074-2:2000, EN 1074-6:2008

Ispitivanje vršeno
Tests performed on

: 02.07.2011 do 19.08.2011

Izveštaj sačinio
Report made by

: 12.03.2012

Ing. Jozef Chrapka

Odgovorno lice:
Responsible and approval person:

12.03.2012

Peter Summer
Načelnik laboratorije za ispitivanje TZBaS
Head of Testing Lab. TZBaS


Napomena: Srpski tekst ovog izveštaja je prevod sa Engleskog teksta.
U slučaju spora samo Engleski tekst ovog izveštaja se smatra validnim.

Note: Serbian text of this report is a translation of the English text. In case of doubt only English text of this report is valid.



TSÚ Piešťany š.p. skúšobňa TZBaS	zadatok:	112100004
	strana	2 od 10
IZVEŠTAJ O ISPITIVANJU FUNKCIONALNIH I RADNIH KARAKTERISTIKA TEST REPORT ON FUNCTIONAL AND OPERATIONAL PROPERTIES Br. / No. 112100004/314/2		

OPIS PROIZVODA / **PRODUCT DESCRIPTION**



Požarni hidrant tip NH21A5 (tip "A" prema stand. EN 14384), DN 100, PN 16 sastoji se od gornje razvodne glave sa izlazima 2 x 65 mm + 1 x 100 mm, donjeg tela zatvarača, oboje su napravljeni od livenog gvožđa GJS 500-7 (GGG50) i od hidrantskog stuba koji je napravljen od nerđajućeg čelika. Površina hidranta je zaštićena od korozije sa plavo/sivom farбом. Crtež hidranta se nalazi u aneksu ovog izveštaja. Hidrant se može koristiti u vodi za ljudsku upotrebu pod uslovom da su korišćeni materijali, uključujući lubrikante, koji dolaze u kontakt sa vodom za ljudsku upotrebu, usaglašeni sa Nacionalnim propisima zemlje u kojoj se koriste.

The pillar fire hydrant type NH21A5 (type „A“ acc. to EN 14384), DN 100, PN 16 consists of the upper distribution head with outlets 2 x 65 mm + 1 x 100 mm, bottom obturator's bod, both of them are made of cast iron GJS 500-7(GGG50) and of a stainlesssteel pipe as a hydrant's column. The hydrant's surface is protected against corrosion with blue / gray paint. The hydrant's drawing is in the annex of this report. The hydrant could be used for water assigned for human consupcion under condition that used materials, including lubricants, coming into contact with water for human consupcion, shall comply with tha National regulations in the country of use.

POSTUPAK I REZULTATI ISPITIVANJA, MERENJA I ZAKLJUČAK:

PROCESS AND RESULTS OF TESTS, MEASURING AND FINDING

Korišćena metoda ispitivanja: EN 14384: 2005, EN 1074-6:2008 i odgovarajući standardi /and related standards

Used test method MPS 314/1.2.1, MPS 314/2.2.1 a MPS 314/3.1.1

1. Pouzdanost u radu /Operational reliability

Stavka br. Item No	Zahtev/Requirement	Usaglašeno sa zahtevom Compliance with the requirement
Konstrukcija /Design		
EN 14384:2005 čl. 4.2 – Omotač / Shell:		
1.	Omotač nadzemnog hidranta mora biti napravljen od datih materijala / <i>The shell of the pillar hydrants shall be made of the given materials :</i>	X
	– Liveno gvožđe sa lamelarnim grafitom / <i>Flake graphite cast iron EN 1503-3, ili / or</i>	(Upper and bottom body)
	– Liveno gvožđe sa sfernim grafitom / <i>Spheroidal graphite cast iron EN 1503-3, ili / or</i>	+
	– Čelik / <i>Steel EN 1503-1</i>	(column – pipe –steel) +
EN 14384: 2005 čl. 4.3 – Elastomeri / Elastomers:		
2.	Svi zaptivači od elastomera u hidrantu moraju biti usaglašeni sa EN 681-1/ <i>All elastomeric seals within the hydrant shall complay with EN 681-1.</i>	X
	– Zaptivači moraju biti bilo tipa WA za hladnu pijaću vodu, ili / <i>The seals shall be either type WA for cold potable water, or</i>	
	– Odgovarajući za fluid sa kojim dolaze u kontakt / <i>Suitable for the fluid with which they come into contact</i>	+

Nastavak tabele na strani 3 / *The table continues on 3rd page*

TSÚ Piešťany š.p. skúšobňa TZBaS	zadatok:	112100004
	strana	5 od 10
IZVEŠTAJ O ISPITIVANJU FUNKCIONALNIH I RADNIH KARAKTERISTIKA TEST REPORT ON FUNCTIONAL AND OPERATIONAL PROPERTIES Br. / No. 112100004/314/2		

Nastavak tabele sa strane 4 / The table continuation from 4th page

EN 14384: 2005 čl. 4.6.3.2 Mehanička čvrstoća / Mechanical strength:					
12.	Tokom ispitivanja na hidrantu ne sme biti vidljivih tragova defekata / During the test the hydrant shall not present any sign of defect			+	
EN 14384: 2005 čl. 4.8 Smer zatvaranja / Closing direction					
13.	Hidrant se zatvara u smeru kazaljke na satu / The hydrant shall be closed in a clockwise direction.			+	
EN 14384: 2005 čl. 4.9 Broj okretaja otvaranja / Opening turns					
14.	Oznaka otvaranja na gornjem delu hidranta će obuhvatati / The opening mark on the upper part of the hydrant shall include:			+	
	– Ukupan broj okretaja (N, sa tolerancijom od ± 1) do potpunog otvaranja / Total number of turns (N, with a tolerance of ± 1) to fully open			+	
15.	– Znak smeru otvaranja - označen strelicom / Mark of opening direction – marked by arrow			+	
	Proizvođač treba da objavi / The manufacturer shall declare:			+	
	– Broj okretaja uređaja za otvaranja od početka protoka do potpunog otvaranja (efektivni okretaji): $N=9$ / The number of turns of the opening device from commencement of flow to fully open (effective turns): $N = 9$			+	
	– Broj okretaja uređaja za otvaranje pre početka protoka (prazni okretaji): $N_0 = 1$ / The number of turns of the opening device prior to the commencement of flow (dead turns): $N_0 = 1$			+	
– Zbir okretaja (ukupan broj okretaja): $N=10$ / Addition of the turns (total turns): $N = 10$					+
EN 14384:2005 čl. 4.10 Otpornost hidranta na radno opterećenje / Resistance of the hydrant to operating loads					
EN 14384:2005 čl. 4.10.1 Maksimalni radni obrtni moment (MOT) za radno opterećenje: / Maximum operating torque (MOT) for operating loads:					
16.	Obrtni moment potreban za zatvaranje hidranta / The torque to seal the hydrant shall meet :				
	Maksimalni radni obrtni moment Nm Maximum operating torque				
	Nominalna veličina hidranta (DN) Nominal size of the hydrant	80	100	150	
	Klasa obrtnog momenta 1 Torque range 1	80	80	80	
	Klasa obrtnog momenta 2 Torque range 2	125	125	125	
	Klasa obrtnog momenta 3 Torque range 3	105	130	195	
	Izmereni radni podaci / Measured data of operating				
	Predmet ispitivanja (br. tipa proizvoda) Tested Object (Product Type No.)	Nominalna veličina hidranta Nominal size of the hydrant DN	Radni obrtni moment Operating torque (Nm)		
	tip NH21A5 DN 100, PN 16	DN 100	125 Nm		

Nastavak tabele na strani 6 / The table continues on 6 th page

TSÚ Piešťany š.p. skúšobňa TZBaS	zadatok:	112100004
	strana	6 od 10
IZVEŠTAJ O ISPITIVANJU FUNKCIONALNIH I RADNIH KARAKTERISTIKA TEST REPORT ON FUNCTIONAL AND OPERATIONAL PROPERTIES Br. / No. 112100004/314/2		

Nastavak tabele sa strane 5 / The table continuation from 5th page

EN 14384:2005 čl. 4.10.2 Minimalni obrtni moment čvrstoće (mST) / Minimum strength torque (mST)										
17.	Otpornost hidranta kada je opterećen obrtnim momentom / The resistance of the hydrant when stressed by the torque:									
	Minimalni obrtni moment čvrstoće (Nm) Minimum strength torque									
	Nominalna veličina hidranta (DN) Nominal size of the hydrant		80	100	125					
	Klasa obrtnog momenta 1 Torque range 1		250	250	250					
	Klasa obrtnog momenta 2 Torque range 2		250	250	250					
	Klasa obrtnog momenta 3 Torque range 3		210	260	380					
	Ne sme biti vidljivih tragova deformacije tokom, i nakon, ispitivanja obrtnim momentom od 250 Nm / No visible sign of deformation during and after the test when stressed by 250 Nm torque.					+				
EN 14384:2005 čl. 4.18 Otpornost na dezinfekcione proizvode / Resistance to disinfection products:										
18.	Ne sme biti curenja na zatvaraču nakon ispitivanja otpornosti na dezinfekcione proizvode / No leakage of the obturator after the test of resistance to disinfection products								Nije ispitano Not tested	
EN 14384:2005 čl. 4.17 Hidranti za sisteme sa vodom koja nije za piće / Hydrants for non-potable water systems:										
19.	U slučaju kada hidrant transportuje vodu koja nije namenjena za ljudsku upotrebu proizvođač mora obezbediti da svi materijali koji se koriste u hidrantu, kada dođu u kontakt sa fluidom, neće biti ugroženi uticajem tog fluida / In the case where the hydrant does not transport water intended for human consumption, the manufacturer shall ensure that all materials used in the hydrant where they come into contact with the fluid, shall not be adversely affected by that fluid.								+	
EN 14384:2005 čl. 4.20 Hidraulične karakteristike / Hydraulic characteristics:										
20.	Minimalna vrednost Kv ne sme biti manja od / The minimum value Kv shall not be less than:									
	DN	Veličina i broj izlaza koji se ispituju / Size and number of outlets to be tested								
		1x37,5	2x37,5	1x50	2x50	1x65	2x65	1x100	2x100	1x150
	80 i 100	30	60	40	60	80	140	160 ¹	-	-
	150	-	-	-	-	80	140	160	280	300
	¹ Ne primenjuje se za DN 80 / Does not apply for DN 80									
	- Kombinacija DN i veličina izlaza nije dozvoljena / Combination of DN and size of the outlet not allowed									
Izmereni Kv / Measured Kv:									+	
Predmet ispitivanja (br. tipa proizvoda) Tested Object (Product Type No.)	DN hidranta	Veličin i broj izlaza Size and number of outlets		Izmereno Kv (presečna vrednost, 11 merenja) Measured Kv (average value of 11 measuring)						
tip NH21A5	DN 100	2 x 65 1 x 100		265 252						
									+	

TSÚ Piešťany š.p. skúšobňa TZBaS	zadatok:	112100004
	strana	7 od 10
IZVEŠTAJ O ISPITIVANJU FUNKCIONALNIH I RADNIH KARAKTERISTIKA TEST REPORT ON FUNCTIONAL AND OPERATIONAL PROPERTIES Br. / No. 112100004/314/2		

2. Dimenzije priključaka /Connection dimensioning

Stavka br. Item No	Zahtev /Requirement	Usaglašenost sa zahtevom Compliance with the requirement
EN 14384:2005 čl. 4.12 Ulazni priključci / Inlet connections:		
1.	Ulazne priрубnice moraju biti usaglašene sa / Inlet flanges shall conforming with : – EN 1092-1 za omotače napravljene od čelika / for shell made of steel	X
	– EN 1092-2 za omotače napravljene od sivog liva / for shell made of cast iron	+
EN 14384:2005 čl. 4.13 Izlazi / Outlets:		
2.	DN tela mora biti jednak, ili veći, od DN-a izlaza / DN of the body has to be equal or bigger than DN of the outlets	+
3.	Broj izlaza mora biti minimum dva za DN 150 / Number of outlets has to be at least two for DN 150	X
4.	Konstrukcija izlaza mora biti usaglašena sa važećim nacionalnim zahtevima zemlje u kojoj se koristi / The design of the outlets shall conform to national requirements valid in the country of use	X

3. Trajnost radne pouzdanosti protiv korozije / Durability of operational reliability against corrosion

Stavka br. Item No	Zahtev /Requirement	Usaglašenost sa zahtevom Compliance with the requirement
EN 14384:2005 čl. 4.16 Unutrašnja i spoljna otporn. na koroziju / Internal and external corrosion resistance		
EN 14384:2005 čl. 4.16.1 Opšte / General		
1.	Unutrašnje površine, koje su u konstantnom kontaktu sa vodom, moraju biti otporne na koroziju i starenje odabirom odgovarajućih materijala / The internal surfaces which are in continuous contact with the water shall be resistant to corrosion and ageing by appropriate selection of materials	+
2.	Spoljne površine, uključujući zavrtnjeve, koji su u konstantnom kontaktu sa okolnim tlom, vodom ili atmosferom, moraju biti otporne na koroziju i starenje odabirom odgovarajućih materijala / The external surfaces, including bolts, which are in continuous contact with the surrounding soil, water or atmosphere, shall be resistant to corrosion and ageing by appropriate selection of materials	+
EN 14384:2005 čl. 4.16.2 Premazi / Coatings		
3.	Svi delovi od sivog liva moraju biti premazani radi zaštite od korozije, po potrebi / All cast iron components shall be coated to protect against corrosion, if applicable	+
EN 14384:2005 čl. 4.15.3 Ostale komponente / Other components		
4.	Ostali sastavni delovi hidranta, pored onih u 4.16.1, moraju biti proizvedeni od materijala koji su otporni na koroziju za radni vek proizvoda pod uslovima upotrebe za koju su namenjeni / Other component parts of the hydrant to those in 4.16.1 shall be manufactured from materials that will resist corrosion for the design life of the product under the conditions of the use for which it is intended.	+

IZVEŠTAJ O ISPITIVANJU FUNKCIONALNIH I RADNIH KARAKTERISTIKA
TEST REPORT ON FUNCTIONAL AND OPERATIONAL PROPERTIES
Br. / No. 112100004/314/2



Ispitivanje hidrauličnih karakteristika izlaza 2x65 / Testing of hydraulic characteristics of outlets 2x65



Ispitivanje hidrauličnih karakteristika izlaza 1x100 / Testing of hydraulic characteristics of outlet 1x100

TSÚ Piešťany š.p. skúšobňa TZBaS	zadatok	112100004
	strana	9 od 10
IZVEŠTAJ O ISPITIVANJU FUNKCIONALNIH I RADNIH KARAKTERISTIKA TEST REPORT ON FUNCTIONAL AND OPERATIONAL PROPERTIES Br. / No. 112100004/314/2		

4. Trajanje radne pouzdanosti, izdržljivost / Durability of operational reliability, endurance

Stavka br. Item No	Zahtev/Requirement				Usaglašenost sa zahtevom Compliance with the requirement
EN 14384:2005 čl. 4.6.4 Radni ciklusi, izdržljivost / Operating cycles, endurance					
1.	Uslovi ispitivanja izdržljivosti / Test condition of the endurance test usaglašeni sa 5.5.1 (EN 1074-6:2004 i aneksom D)/in accordance with 5.5.1 EN 1074-6:2004 and Annex D):				
	Predmet ispitivanja (br. tipa proizvoda) Tested Object (Product Type No.)	Uslovi ispitivanja / Test conditions			+
		MOT	PFA	Temperatura tečnosti	
	NH21A5, DN100 PN 16	125 Nm	1,6 MPa	19,5 °C	
	Ocena ispitivanja / Evaluation of test:				
	Nepropusnost kada je unutrašnji pritisak jednak sa PEA / Tightness when inside pressure is equal to PEA:				
	Uslovi ispitivanja / Test conditions				
	Pritisak ispitivanja Test pressure (PEA)	Tečnost ispitivanja Testing liquid	Temperatura tečnosti / Testing liquid temperature	Trajanje ispitivanja Test duration	+
	2,5 MPa	voda / water	19,5 °C	600 s	
	Tokom ispitivanja curenja na hidrantu ne sme biti vidljivih tragova defekta / During the leakage test the hydrant shall not present any sign of defect				
	Nepropustnost zaptivača kada je unutrašnji pritisak jednak sa 1,1 PFA / Tightness of the obturator when inside pressure is equal to 1,1 PFA				
	Uslovi ispitivanja / Test conditions				
	Pritisak ispitivanja Test pressure	Tečnost ispitivanja Testing liquid	Temperatura tečnosti /Testing liquid temperature	Trajanje ispitivanja Test duration	Curenje Leakage
	1,76 MPa	voda / water	19,5 °C	600 s	0,0
	Na hidrantu ne sme biti vidljivih tragova curenja tokom ispitivanja / The hydrant shall not present visible sign of leakage past the valvet during the test				

Legenda:

- + ispunjava / meets
- ne ispunjava / does not meet
- X nije ispitano, zahtev se ne odnosi na proizvod / not tested, the requirement does not involve the product

TSÚ Piešťany š.p. skúšobňa TZBaS	zadatok	112100004
	strana	10 od 10
IZVEŠTAJ O ISPITIVANJU FUNKCIONALNIH I RADNIH KARAKTERISTIKA TEST REPORT ON FUNCTIONAL AND OPERATIONAL PROPERTIES Br. / No. 112100004/314/2		

Dodatni podaci / Furthermore data:

Korišćena oprema i merači za ispitivanje / Used testing equipment and measures:

1. manometar (0 – 4) MPa, 1%, br. 314/052, važnost kalibracije do 03.02.2017
2. manometar (0 – 1,0) MPa, 1%, br. 314/045, važnost kalibracije do 22.01.2015
3. manometar (0 – 1,0) MPa, 1%, br. 316/021, važnost kalibracije do 22.01.2015
4. manometar (0 – 1,0) MPa, 1%, br. 314/022, važnost kalibracije do 22.01.2015
5. štoperica SECCO br. 314/178, 0 – 24 tačnost $\pm 0,1$ s., važnost kalibracije do 20.10.2016
6. merač protoka KROHNE br.316-013, (21,1 – 211) l/s., 0,5 %, važnost kalibracije do 16.12.2016
7. merač obrtnog momenta br. SM 314/106, (0 – 500) Nm, 0,5%, važnost kalibracije do 17.01.2017.

ZAKLJUČAK / Closure

Rezultati ispitivanja - ispunjava / ne ispunjava zahteve / Test result – meets / does not meet requirements :

Naziv ispitivanja / Name of the test	Tehnička specifikacija/ Technical specification	ispunjava / ne ispunjava meets / does not meet
Radna pouzdanost / Operational reliability:		
- konstrukcija / construction	4.2	+
	4.3	+
	4.4	+
	4.11	X
	4.14	+
	4.15	+
	4.17	+
- pritisci / pressures	4.6	+
- smer zatvaranja / direction of closure	4.8	+
- broj okretaja otvaranja / number of opening turns	4.9	+
- otpornost hidranta na radna opterećenja / resistance of hydrant to operating loads	4.10	+
- otpornost na dezinfekcione proizvode / resistance to disinfection products	4.18	X
- hidranti za sisteme sa vodom koja nije za piće / hydrants for non potable water system	4.19	+
- hidraulične karakteristike / hydraulic characteristic	4.20	+
Dimenzije priključaka / Connection dimensioning	4.12; 4.13	+
Trajnost radne pouzdanosti protiv korozije / Durability of operational reliability against corrosion	4.16	+
Trajnost radne pouzdanosti, izdržljivost / Durability of operational reliability, endurance	4.6.4	+

Legenda: + ispunjava / meets
 – ne ispunjava / does not meet
 X nije ispitano / not tested

Peter Summer
 Načelnik laboratorije za ispitivanje TZBaS/
 Head of Testing Lab. TZBaS